



INSTITUTE OF NANO SCIENCE AND TECHNOLOGY, MOHALI

(An autonomous Research Institute of Department of Science and Technology,
Government of India)

Habitat Centre, Sec-64, Phase X, Mohali – 160062, PUNJAB

Phone No: 0172 – 2210073/74/75, Fax No: 0172 – 2211074

Website: www.inst.ac.in

Ref No. INST/12(34)/2020-Pur

Date: 15/07/2020

CORRIGENDUM

Reference to NIT no. INST/12(34)/2020-Pur published in national newspapers for purchase of Lab Furniture. Below mentioned technical points may be read and corrected as per following:-

In reference to the Pre-bid Queries, please find the details as asked in queries.

S. No.	Present Specification	Clarification after pre-bid meeting
1	LABORATORY FURNITURE & ACCESSORIES: The entire laboratory furniture should be tested as per SEFA-8M standards in SEFA approved labs with latest 2016 Guidelines published by SEFA	The entire laboratory furniture should be tested as per SEFA standards.
2	Page No. 34(Lab furniture specification- MOC should be CRCA/GI epoxy powder coating	No change (Clarified in pre-bid meeting)
3	Fume Hood Sash: 5 mm thick toughened glass in frameless const. and vertical rising type and combination type arrangements. Fume Hood sash works with a pulley & counter weight mechanism with SS 316, multi wire flexible sash rope	Any one of them Sash pulley / chain sprocket system
4	CERTIFICATIONS : OEMs (Vendors/Bidders) should have valid i) ISO – 9001: 2015 ; ISO – 14001:2015 ; OHSAS 18001:2007 certification / certified company; ii) should submit third party Test certificate of “BIFMA HCF 8.1” by approved agency ; IGBC CERTIFICATE in technical bid and iii) should also have valid SEFA Membership for minimum 9 (Nine) consecutive years and valid ASHRAE Membership certificate for Fume Hoods	No change (Clarified in pre-bid meeting)
5	FINANCIAL TURNOVER : Vendors / Bidders should have had an average annual financial turnover of Rs.30 Crs. (Thirty Crores) in last 3 (three) years i.e. 2016-17 ; 2017 -18 ; 2018 - 19 ending 31 st March ,2020 .The Group turnover of any other business other than Fume Hoods, Exhaust	Vendors / Bidders should have had an average annual financial turnover of Rs.16 Crs. (Sixteen Crores) in last 3 (three) years i.e. 2016-17 ; 2017 -18 ; 2018 - 19 ending 31 st March ,2020



INSTITUTE OF NANO SCIENCE AND TECHNOLOGY, MOHALI

(An autonomous Research Institute of Department of Science and Technology,

Government of India)

Habitat Centre, Sec-64, Phase X, Mohali – 160062, PUNJAB

Phone No: 0172 – 2210073/74/75, Fax No: 0172 – 2211074

Website: www.inst.ac.in

	Systems , Gas distribution Systems (GDS), Electrical work and Laboratory Furniture cannot be included. Latest audited financial statement with CA certificate to this effect may be submitted.	
6	INFRASTRUCTURE : The Vendor / Bidder or its parent company should have a well – established (their own) in – house manufacturing unit for the steel Laboratory Furniture and Fume Hoods, quality management system as per International Standards providing the products and services on the continuous basis at least for the last 15 years	The experience of company as 10 years instead of 15 years.
7	In Bench Fume Hood: In drawing of FH (A) a bench fume hood with 2 nos cabinet one is with vacuum pump provision and other is with FRP liner cabinet. Any air ventilation required in the below Fume Hood cabinet.	Yes air ventilation required in the below Fume Hood cabinet.
8	Drawings of Laboratory Work Tables The drawings mentioned are with sliding cabinets. Please confirm whether to consider the sliding type cabinet or hanging type cabinet	Only hanging type Cabinet is required.
9	Page No. 20 of 34 Technical Specification of exhaust fan The specifications mentioned in fume hood inner lining is 6mm thick panels made of laboratory grade Phenolic Resin / Compact Laminate phenolic resin Please specify phenolic resin to be considered or compact laminate to be considered .	Only Phenolic Resin boards is required.
10	Page No. 22 of 34 Technical Specification of exhaust fan The Specifications mentioned of exhaust fan is with DOL starter for motor / Electrical panel with necessary internals and VFD for fan. Please confirm whether to consider DOL starter or VFD in exhaust fan	DOL Starter (Make: L&T, BCH or Havells)
11	The scope also includes internal wiring of Electrical Switch & Sockets	Electrical wiring should be connected upto DB boxes.



INSTITUTE OF NANO SCIENCE AND TECHNOLOGY, MOHALI

(An autonomous Research Institute of Department of Science and Technology,

Government of India)

Habitat Centre, Sec-64, Phase X, Mohali – 160062, PUNJAB

Phone No: 0172 – 2210073/74/75, Fax No: 0172 – 2211074

Website: www.inst.ac.in

	located at the triangular raceway provided above the worktop of Laboratory Furniture and the same should be connected to the DB nearest to the position of the item.	
12	Tender Fees Please clarify whether we can get the tender fees exemption against submission of NSIC certificate.	As per GOI guidelines.
13	Tender submission in Off-line Two - Bid Tender	Yes offline tender
14	Taxes: INST is having exemption of payment of Excise Duty under notification number 10/97 dated 01.03.1997 and Customs Duty under notification No.51/96 dated 23.07.1996. Hence Excise Duty and Customs Duty, if any, should be shown separately. Please mention the applicable taxes (VAT/Service Tax etc.) clearly. We don't issue any 'Form C' or 'Form D'. If there is no explicit mention of taxes in your offer then quoted price will be deemed inclusive of such taxes. No other charges except those mentioned clearly in the quotation will be paid.	INST is registered with Department of Scientific & Industrial Research (DSIR) for purposes of availing Customs Duty Exemptions in terms of notification No: 51/96 – Customs dated 23.07.1996, Notification No: 28/2003-customs dated 01.03.2003, Notification No: 43/2017 - customs dated 30.06.2017, Notification No: 47/2017-Integrated Tax (Rate) dated 14.11.2017, Notification No: 10/2018-Integrated Tax (Rate) dated 25.01.2018, and Notification No: 45/2017-Central Tax (Rate) dated 14.11.2017, Notification No: 45/2017 – Union Territory Tax (Rate) dated 14.11.2017 & Notification No: 9/2018 – Central Tax (Rate) dated 25.01.2018, Notification No: 9/2018 – Union Territory Tax (Rate) dated 25.01.2018, as amended from time to time for research purposes only.
15	A list of 10 installations in India (Particularly Govt of India R&D organisations), provide the name-wise list of Institute/Laboratory with date and value of supply	A list of 10 installations in India (Particularly Central Govt./PSUs/Autonomous bodies/National R&D laboratories/Academic Institutes of higher learning/education (like doctoral & postdoctoral) conducting wet lab research.
16	The manufacturing firm should be ISO/CE/SEFA Certified	CE certification not considered. ASHRAE 110-2016/EN 14175 certificate should be enclosed along with the bid
17	LABORATORY FURNITURE & ACCESORIES	GI/MS with appropriate treatment may be considered.



INSTITUTE OF NANO SCIENCE AND TECHNOLOGY, MOHALI

(An autonomous Research Institute of Department of Science and Technology,
Government of India)

Habitat Centre, Sec-64, Phase X, Mohali – 160062, PUNJAB

Phone No: 0172 – 2210073/74/75, Fax No: 0172 – 2211074

Website: www.inst.ac.in

	The laboratory furniture should be modular construction & design made of mainly Skin Passed / Zero Spangle G.I. (Galvanized Iron) duly coated with at least 50-60 micron Epoxy Powder coated in panel form and in CKD (Completely Knocked Down) construction so it can be erected at site as per attached layout	
18	VENDORS / BIDDERS ELIGIBILITY CRITERIA The product shall be tested in the Manufacturer's own test facility for it's evaluation as per ASHRAE – 110 - 2016 (USA Standards)	ASHRAE 110-2016/EN 14175 certificate should be enclosed along with the bid.
19	Multiple currency option for the commercial bidding.	Currency other than INR also will be considered.

Other specifications and terms & conditions remains the same. Bidders submit the tender within due date and time i.e. on or before 10/08/2020 till 2:30 PM.

Sd/-
Head of Office